



Prairie Band of Potawatomi Nation
16281 Q Road, Mayetta, KS 66509
Phone: (785)966.4000 • Fax: (785)966.3062

ADDENDUM NO. 1

“PBPN Road Repair, Full Depth Replacement”

RFP# 2022-CM006

1. Notice to Respondents

The Request for Proposal (RFP) is modified as set forth in this Addendum. This addendum shall hereby be made a part of the RFP documents and is issued to change, amplify, or delete from or otherwise explain these documents where provisions of this addendum differ from those of the original documents. This addendum shall have precedence over the original documents and shall govern.

2. Pre-Bid Conference Questions and Answers

The following information is provided as a matter of information to clarify issues raised about the RFP. To the extent that changes to the RFP are required based on the questions received, the RFP has been modified as noted.

2.1. Questions:

Q1. The scale of the prints are not correct.

A1. Please see Attachment “A” of this addendum for updated drawings with corrected Scale.

Q2. Budget – 1A does not include mobilization on each road section. If bid separate can this be added?

A2. Please See Attachment “B” of this addendum for updated budget B-1A.

Q3. Patch details and specifications. Question of depth of patch as there is a discrepancy between drawings and Attachment “J”.

A3. Follow drawing detail and not Attachment “J” as to the required or allowed depth of patching.

Q4. Additional pavement removal at patch locations.

A4. Cut paving 6” larger than damaged area.

Q5. Add Alternates 150th & 158th from KDOT ROW to PBPN boundary and Gas station does not show any patch and repair. Is this included?

A5. Yes, Patching and repair will be completed as necessary on these road sections.

Q6. Shoulder work along 150th what grade or slope for shoulders?

A6. Typical shoulder along 150th and keep the existing slope.

The following changes have been made to the RFP:

- Updated drawing has been included which has the corrected scale.
- Correction made to Attachment "B" B-1A worksheet

CONFIDENTIALITY

The Contractor shall maintain all non-public information secured in connection with any contract with PBBN in strict confidence, with disclosure only to individuals as needed to perform under the contract and on a need-to-know basis.

All other provisions shall remain in their entirety.